Tes

T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

B-0963

Item No.

Model is Available as B-0963-RK

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

	This Space for	This Space for Architect/Engineer Approval	
3 3/8"	Job Name	Date	
86mm J	Model Specified	Quantity	
	Customer/Wholesale	er	
	Contractor		
	Architect/Engineer_		
	1/2" NPT Female Outlet	Repair Kit For This	

Ø 2" [51mm] Always Install Vacuum Breaker in Upright Position (As Shown) 5 11/16" Bleeder [145mm] Screw 4 3/16" [106mm] Field Test Cock 0 (2) Quarter-Turn Shutoff Valve 1/2" NPT Female Inlet

Product Specifications:

Continuous Pressure Vacuum Breaker, 1/4 Turn Ball Valves, Bleeder Screw.

Test Cock & 1/2" NPT Female Inlet & Outlet

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ASSE 1056 (VB)

Drawn: JBC | Checked: JRM | Approved: JHB | Date: 04/12/16 | Scale: 1:2 | Sheet: 1 of 1