# Tes

Drawn:

MRC

Checked:

JRM

Approved:

JHB

Date:

## T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

EC-3100-LF22-SB

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

Travelers Rest, 5C. 800-476-4103 • Simi Valley, CA. 800-425-0150 • Fax. 804-854-3518 • www.tsbrass.com				
ChekPoint*		This Spa	This Space for Architect/Engineer Approval	
	• 1	Job Name		Date
ADA Compliant	2 1/4"	Model Specifi	ed	Quantity
	[57mm]	- a ur		
<b>†</b> (1)		Contractor		
2 1/2"		Architect/Eng	ineer	
[63mm]	—018052-40 Rigid Surgical Bend Now/ 2.2 GPM [8.3 L/min Vandal Resistant Lami Flow Device.			
Available Outlet Option B-0103-F Series Flow Control Rosespray Outlet	3 5/8" x 4 3/16" x 2" De [92mm x 106mm x 51m Water Resistant Control Module Box (Grey) w/ Internal Flow Control Setting Switches, AC or DC operated w/ (4) AA Batteries. Hardwire Capusing Terminals on Back	m] —	7 1/16" [180mm]	13" 32mm]
1/2" NPSM x 1/4" NPSM— 18" [457mm] Flexible	24" [610mm] Sensor Cable Removable Strainer	Mounting Surface  2 1/4"  [57mm]  Maximum Thickness	7 5/8"  93mm]	✓ 1/8" [3mm] Anti-rotation Pin. Remove Pin if Desired. (See Mounting Hole Detail)
Stainless Steel Hose		w/ 71" [1800mm] F Cord.(Remove Rul Plugs on Module a Cable to Connect)	ower   bber Ind	Mounting Hole Detail
Temperature Mixing Valve w/ Check Valves	18"	3/8" Compression x 1/ [457mm] Flexible Stai oply Hose		1" [25mm] $\phi$ 5/32" [4mm]
Product Specifications:			Product Compliance:	
Chrome Plated Brass Electronic Faucet: Deck Mount Rigid Surgical Bend Nozzle w/ VR Laminar Flow Device, AC/DC Control Module with Internal Flow Control Setting Switches, Temperature Control Mixing Valve w/ Check Valves & 18" Hot & Cold Supply Hoses  ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA)				

UL 1951

Scale:

1:8

Sheet: 1 of 2

08/23/19



## T&S BRASS AND BRONZE WORKS, INC.


2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

Model No.


EC-3100-LF22-SB

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com



ITEM NO.	SALES NO.	DESCRIPTION	
1	B-0199-21-VRF	VR Device, 2.2 GPM, Laminar Flow, 55/64-27	
2	044A	3/8" to Aerator Adapter	
3	006575-45	O-Ring	
4	016297-45	Inlet Hose, Faucet, 1/2" NPSM-F x 1/4" NPSM-F	
5	016647-45	ChekPoint Module (Grey)	
6	5EF-0002	A/C Transformer	
7	5EF-0005	Supply Hose, 9/16-24 Female x 1/2" NPSM	
8	5EF-0006	Mechanical Mixing Valve	
9	015425-45	Vandal Resistant Key	
10	017195-45	Angled Sensor w/ Cable	
11	018052-40	Rigid Surgical Bend Nozzle w/ 2.2 VR Laminar Flow Device	
12	EC-FILTER	Replacement Filter	



A Maximum of (8) ChekPoint Faucets can be Hardwire Connected and Powered by EC-HARDWIRE ChekPoint Hardwire AČ Transformer. (Sold Separately)



Flow Control Switches are Located Inside Module Housing in Black Box Next to Battery Compartment.
\*Switches are Set to DEFAULT Position:

- - Auto Time Out = 15 Seconds
  - Shut Off Delay = 1 Second
  - Auto Flush = OFF

Remove (4) Screws and Back Cover to Access Switches.

#### \*Available Water Flow Control Selections:

- Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min
- Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF

#### **Product Specifications:**

Chrome Plated Brass Electronic Faucet: Deck Mount Rigid Surgical Bend Nozzle w/ VR Laminar Flow Device, AC/DC Control Module with Internal Flow Control Setting Switches, Temperature Control Mixing Valve w/ Check Valves & 18" Hot & Cold Supply Hoses

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951

Drawn: MRC Checked: JRM Approved: Date: 08/23/19 Scale: NTS Sheet: 2 of 2